



www.nemko.com

TEST REPORT IEC / EN 62208 Empty enclosures for low voltage switchgear and controlgear assemblies – General requirements				
Report Reference No	284229B			
Tested by (name + signature)	Tom Ingebrigtsvold			
Witnessed by (name + signature):	Tore Ledaal			
Supervised by (name + signature):	lore Ledaal			
Approved by (name + signature):				
Date of issue	16.09.2015			
CB Testing Laboratory	NEMKO AS			
Address	Gaustadalléen 30, 0373 Oslo, NORWAY			
Testing location/ procedure	CBTL 🛛 RMT 🗌 SMT 🗌 WMT 🗌 TMP 🗌			
Applicant's name	Multilux AS			
Address	Sandavegen 19, 3802 Bø i Telemark NORWAY			
Test specification:				
Standard	IEC 62208:2011 / EN 62208:2011			
Test procedure	CB / CCA			
Non-standard test method	N/A			
Test Report Form No	IECEN62208A			
TRF Originator	OVE			
Master TRF	Dated 2004-07			
Copyright © 2004 IEC System for Co (IECEE), Geneva, Switzerland. All rig	onformity Testing and Certification of Electrical Equipment ghts reserved.			
acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.				
Test item description				
Trade Mark:	Multilux			
Manufacturer	Multilux AS, Sandavegen 19, 3802 Bø i Telemark, NORWAY			
Model/Type reference	MU series			
Ratings	600-838-250			

This Test Report, when bearing the Nemko name and logo is only valid when issued by a Nemko laboratory, or by a laboratory having special agreement with Nemko.



Calibration	All instruments used in the tests given in this test report are calibrated and
	traceable to national or international standards.
	Further information about traceability will be given on request.
Measurement	Measurement uncertainties are calculated for all instruments and instrument
uncertainty	set-ups given in this report. Calculations are based on the principles given in
-	the standard EA-4/02 (Dec. 1999), IEC Guide 115:2007, Nemko routine L227
	and other relevant internal Nemko-procedures.
	Further information about measurement uncertainties will be given on request.
Evaluation of results	If not explicitly stated otherwise in the standard, the test is passed if the
	measured value is equal to or below (above) the limit line, regardless of the
	measurement uncertainty. If the measured value is above (below) the limit line
	the test is not passed - ref IEC Guide 115:2007 and Nemko routine   220 The
	instrumentation accuracy is within limits agreed by IECEE_CTL (ref. Nemko
	routing 1.227)
Factory	
	Multilux AS
	Sandavegen 19
	3802 Bø i Telemark
	Norway



ſ

Summary of te	esting:
Sub clause:	Test
9.3	Static loads
9.4	Lifting
9.5	Verification of axial loads of metal inserts
9.6	Verification of degree of protection against external mechanical impacts (IK code)
9.7	Verification of degree of protection (IP code)
9.8.1	Verification of thermal stability
9.8.2	Verification of resistance to heat
9.8.3	Verification of resistance to abnormal heat and fire
9.9	Verification of dielectric strength
9.10	Verification of the continuity of the protective circuit
9.11	Verification of resistance to weathering
9.12	Verification of resistance to corrosion
9.2	Marking



Test item particulars ( Classification ):	
Type of material:	i <del>nsulating</del> / metallic / <del>combination of insulating and</del> <del>metallic</del>
Method of fixing:	floor standing / wall mounting / <del>flush mounting</del> / pole mounting
Intended location:	outdoor / <del>indoor</del>
Degree of protection:	IP66 / IK10
Rated insulation voltage (if applicable):	
Possible test case verdicts:	
- test case does not apply to the test object	N/A
- test object does meet the requirement	P(Pass)
- test object does not meet the requirement	F(Fail)
Testing	
Date of receipt of test item	28.04.2015
Date (s) of performance of tests	28.04.2015-18.08.2015
General remarks:	
This report is not valid as a Test Report according CB, CCA) unless signed by an approved Testing I Certificate issued by a National Certification Body	g to a Mutual Recognition Agreement (i.e. IECEE- _aboratory and appended to a corresponding y, signatory to the relevant Scheme.
The test results presented in this report relate only to the This report shall not be reproduced, except in full, with laboratory.	ne object tested. out the written approval of the Issuing testing
"(see Enclosure #)" refers to additional information ap "(see appended table)" refers to a table appended to the	ppended to the report. ne report.
Throughout this report a comma is used as the decim	al separator.
General product information:	
Test report includes this variants	
MU-series:	
MU1 – 600/250x838	
MU2 - 800/400x1200	
MU3 - 800/400x1598	
6 INFORMATION TO BE GIVEN REGAR	

6	INFORMATION TO BE GIVEN REGARDING THE E	INCLOSURE	
6.1	Marking		
	The enclosure shall be marked as follows:		
	<ul> <li>Name, trade mark or identification mark of the enclosure manufacturer.</li> </ul>		Ρ
	<ul> <li>Type designation or identification number of the enclosure.</li> </ul>		Ρ
	The marking shall be durable and easily legible and may be inside the enclosure.		Ρ



	IEC / EN 62208				
Clause	Requirement + Test	Result - Remark	Verdict		
	Compliance is checked according to the test of 9.2 and by inspection.		Р		
	The marking for recycling of plastic parts shall follow ISO / EN ISO 11469.		N/A		
6.2	Documentation				
	The enclosure manufacturer's documentation shall include:				
	<ul> <li>relevant constructional and mechanical characteristics</li> </ul>		Р		
	- material type		Р		
	<ul> <li>instruction necessary for the correct handling, assembling, mounting and service conditions of the enclosure.</li> </ul>		Р		
	- reference to IEC / EN 62208		Р		
	Information concerning the thermal power dissipation relative to the effective cooling surface:				
	- by calculation (e.g. IEC/TR3 60890, CLC/TR 60890)	Method / Standard: Result: see Annex	N/A		
	- by test (e.g. 8.2.1.4 of IEC / EN 60439-1)	Method / Standard: Result: see Annex	N/A		

7	SERVICE CONDITIONS	
	Location for which the enclosure is intended	Р
7.1	Normal service conditions	
7.1.1	Ambient air temperature	
7.1.1.1	<ul> <li>indoor locations (max. +40 °C, average over 24 h</li> <li>= 35°C; lower limit : -5°C)</li> </ul>	Р
7.1.1.2	<ul> <li>outdoor locations (max. +40 °C, average over 24</li> <li>h</li> <li>= 35°C; lower limit : -25°C/ arctic: -50°C):</li> </ul>	Ρ
7.1.2	Atmospheric conditions	
7.1.2.1	- indoor locations (= 50% RH at max. +40°C)	Р
7.1.2.2	- outdoor locations (up to 100% RH at max. +25°C)	Р
7.1.3	Description of location	
	- outdoor locations: additional test according to 9.11 and 9.12	Р
	<ul> <li>indoor locations: additional test according to 9.12.1 a)</li> </ul>	Р
7.2	Special service conditions	N/A
7.3	Conditions during transport and storage	N/A



	IEC / EN 62208				
Clause	Requirement + Test	Result - Remark	Verdict		
8	DESIGN AND CONSTRUCTION				
8.1	General				
	The enclosure constructed of materials capable of withstanding the mechanical, electrical and thermal stresses, as specified in clause 9, as well as the effects of humidity which are likely to be encountered in normal use.		P		
	Protection against corrosion checked by the test of 9.12		Р		
	For enclosures or parts of enclosures made of insulating materials, thermal stability, resistance to heat, fire and weathering shall be verified according to test of 9.8 and 9.11		N/A		
	Where parts of an enclosure are designed to retain current-carrying parts in position, the relevant standard shall apply for their design and verification.		N/A		
8.2	Dimensions				
	Dimensions shall be given in [mm]		Р		
	The external dimensions: height, width and depth are nominal values and shall be indicated in the catalogue of the enclosure manufacturer.	600/250x838mm	Ρ		
	The projection of cable gland plates, removable covers and handles not included in the external nominal dimensions, the dimensions of such included in the manufacturer's documentation.		Ρ		
8.3	Mounting arrangements				
8.3.1	Enclosure				
	The location and means of the enclosure defined in the manufacturer's documentation.		Р		
8.3.2	Equipment mounting surface				
	The location of the equipment mounting surfaces and their means of fixing shall be defined in the manufacturer's documentation.		Р		
8.4	Static loads				
	The enclosure manufacturer specifies, in the documentation, the maximum permissible loads in the enclosure and on its door.		Ρ		
	Compliance checked according to the test of 9.3		Р		
8.5	Lifting and transport support				
	Where required, enclosures are provided with appropriate lifting device or transport means.		P		
	The correct location, installation and thread size of lifting device, if applicable, is given in the manufacturer's documentation		Ρ		



Г

IEC / EN 62208				
Requirement + Test	Result - Remark	Verdict		
Compliance checked according to the test of 9.4		Р		
Access to the interior of the enclosure	1			
A door or removable cover allow adequate access to the protected space. This may only be opened by use of a key or a tool.		P		
Cable gland plates and covers which are removable from the outside require the use of a tool.		Ρ		
Protective circuit				
Metallic enclosures shall ensure the electric continuity.		Р		
- by conductive structural parts of the enclosure		Р		
- by separate protective conductor to earth		Р		
The enclosure manufacturer shall indicate in the technical documentation, if the enclosure itself fulfils the requirements or if and how separate protective conductors to the protective circuits of the installation have to be carried out		Ρ		
After remove of a removable part protective circuit of the remainder shall not be interrupted.		Р		
For lids, doors, removable covers and the like metal hinges may ensure continuity of the protective circuit provided no electrical equipment is attached to them.		Ρ		
Where these are intended for mounting electrical equipment, additional means shall be provided to ensure the continuity of the protective circuit.		Р		
Compliance is checked according to the test of 9.10		Р		
The enclosure manufacturer shall provide means to facilitate the connection of the external protective conductor by the final assembly manufacturer. The location and the designed l <sup>2</sup> t withstand capacity under fault conditions of such means shall be indicated in the enclosures manufacturers documentation.		Ρ		
Dielectric strength				
Enclosure constructed of an insulating material fulfil the dielectric test of 9.9		N/A		
Degree of protection (IK-Code)				
Degree of protection according to IEC / EN 62262	IK10	Р		
Compliance is checked according to the test of 9.6		Р		
Degree of protection (IP-Code)				
Degree of protection according to IEC / EN 60529	IP66	Р		
Compliance is checked according to the test of 9.7		Р		
	IEC / EN 62208           Requirement + Test           Compliance checked according to the test of 9.4           Access to the interior of the enclosure           A door or removable cover allow adequate access to the protected space. This may only be opened by use of a key or a tool.           Cable gland plates and covers which are removable from the outside require the use of a tool.           Protective circuit           Metallic enclosures shall ensure the electric continuity.           - by conductive structural parts of the enclosure           - by conductors to the protective circuit of the installation have to be carried out           After remove of a removable part protective circuit of the remainder shall not be interrupted.           For lids, doors, removable covers and the like metal hinges may ensure continuity of the protective circuit.           Compliance is checked according to the test of 9.10           The enclosure manufacturer shall provide means to facilitate the connection of the external protective conductive circuit aequipment, additional means shall be provided to ensure the continuity of the protective circuit. </td <td>IEC / EN 62208         Requirement + Test       Result - Remark         Compliance checked according to the test of 9.4       Access to the interior of the enclosure         A door or removable cover allow adequate access to the protected space. This may only be opened by use of a key or a tool.       Cable gland plates and covers which are removable from the outside require the use of a tool.         Cable gland plates and covers which are removable from the outside require the use of a tool.       Protective circuit         Metallic enclosures shall ensure the electric continuity.       - by conductive structural parts of the enclosure         - by conductive structural parts of the enclosure       - by separate protective conductor to earth         The enclosure manufacturer shall indicate in the technical documentation, if the enclosure itself fulfils the requirements or if and how separate protective conductors to the protective circuit of the remainder shall not be interrupted.         For lids, doors, removable covers and the like metal hinges may ensure continuity of the protective circuit oc ensure the continuity of the protective circuit equipment, additional means shall be provided to ensure the continuity of the protective circuit.         Compliance is checked according to the test of 9.10         The enclosure manufacturer shall provide means to facilitate the connection of the external protective circuit conductor by the final assembly manufacturer. The location and the designed IP withstand capacity under fault conditions of such means shall be indicated in the enclosure shall not be indicated in the enclosure shall provide means to facilitate the connectio</td>	IEC / EN 62208         Requirement + Test       Result - Remark         Compliance checked according to the test of 9.4       Access to the interior of the enclosure         A door or removable cover allow adequate access to the protected space. This may only be opened by use of a key or a tool.       Cable gland plates and covers which are removable from the outside require the use of a tool.         Cable gland plates and covers which are removable from the outside require the use of a tool.       Protective circuit         Metallic enclosures shall ensure the electric continuity.       - by conductive structural parts of the enclosure         - by conductive structural parts of the enclosure       - by separate protective conductor to earth         The enclosure manufacturer shall indicate in the technical documentation, if the enclosure itself fulfils the requirements or if and how separate protective conductors to the protective circuit of the remainder shall not be interrupted.         For lids, doors, removable covers and the like metal hinges may ensure continuity of the protective circuit oc ensure the continuity of the protective circuit equipment, additional means shall be provided to ensure the continuity of the protective circuit.         Compliance is checked according to the test of 9.10         The enclosure manufacturer shall provide means to facilitate the connection of the external protective circuit conductor by the final assembly manufacturer. The location and the designed IP withstand capacity under fault conditions of such means shall be indicated in the enclosure shall not be indicated in the enclosure shall provide means to facilitate the connectio		



	IEC / EN 62208		
Clause	Requirement + Test	Result - Remark	Verdict

9	TYPE TESTS			
9.2	Marking			
	Marking made by moulding or pressing shall not be submitted to this test.			
	Test: 15 s with water / 15 s with hexane			N/A
	After the test markings easily legible			N/A
9.3	Static loads			
	Enclosure fitted with 1,25 times the maximum load as described in 8.4	Enclosure: Door: kg	kg	N/A
	Loads retained for 1h in the closed position			N/A
	Enclosure constructed of insulating material and metallic enclosures with parts (hinges, locks, etc.) of insulating material tested at 70°C			N/A
	Closed door opened 5 times through 90°			Р
	Resting in open position: 1 min.			Р
	After the test enclosure shows no cracks or permanent distortions			Ρ
	During the test no deflections which could impair any of its characteristics			Ρ
9.4	Lifting			
	Enclosure loaded as in 9.3 with its door closed, lifted with the specified lifting means and in the manner defined by the manufacturer.	Enclosure:	kg	N/A
	3 times: from standstill position to a height of $1 \pm 0.1$ m for 30 min, returning to standstill position			N/A
	3 times: from standstill position to a height of $1 \pm 0.1$ m and moved $10 \pm 0.5$ m horizontally; then set down. One cycle: 1 min $\pm 5$ s at uniform speed			N/A
	After the test enclosure shows no cracks or permanent distortions			N/A
	During the test no deflections which could impair any of its characteristics			N/A
9.5	Verification of axial loads of metal inserts			
	Axial load according to table 2 applied for 10s	Size: M	Load: N	N/A
	After the test:			
- the insert is in its original position				N/A
	- no cracks and splits in the material			N/A
	- no sign of movement			N/A



Г

	IEC / EN 62208			
Clause	Requirement + Test	Result - Remark	Verdict	
9.6	Verification of degree of protection against external mechanical impacts			
	- according to IEC / EN 62282 with a test hammer according to IEC / EN 60068-2-75		N/A	
	Values according to table 3:	IK10 / Impact Energy = 20 J	Р	
	- 3 times to each exposed surfaces in normal use whose largest dimensions is not above 1m		N/A	
	- 5 times to each exposed surfaces in normal use whose largest dimensions is greater than 1m		Р	
	Impacts applied evenly distributed to the faces of the enclosure		Р	
	After the test:			
	- enclosure continue to provide the IP code and dielectric strength		Р	
	- removable covers be removed and reinstalled		Р	
	- doors opened and closed		Р	
9.7	Verification of degree of protection (IP-Code)			
9.7.1.1	.1 Verification of degree of protection against access to hazardous parts			
	Enclosures IPXXA, IPXXB, IPXXC, IPXXD according to 12.1 and 12.2 of IEC / EN 60529.	IP66	Ρ	
	Access probe shall not enter the protected space		Р	
9.7.1.2	Verification of degree of protection against the ingres	ss of solid foreign objects		
	Enclosures IP2X, IP3X, IP4X according to 13.2 and 13.3 of IEC / EN 60529.		N/A	
	Enclosures IP5X according to 13.4 and 13.5 category 2 of IEC / EN 60529.		N/A	
	Enclosures IP6X according to 13.6 of IEC / EN 60529.		Р	
9.7.2	Verification of degree of protection against ingress o second characteristic numeral.	f water as indicated by the		
	Test according to 14.1 and 14.2 of IEC / EN 60529.		Р	
	After the test, water has not ingressed into the protectived space.		Ρ	
9.7.3	Verification of degree of protection against hazardou additional letter.	is parts as indicated by		
	Test according to 15 of IEC / EN 60529.		Р	
	The access probe shall not touch the surface of the protected space.		Р	
9.8	Properties of insulating materials			
9.8.1	Verification of thermal stability			
	Test according to IEC / EN 60068-2-2		Р	



٦

IEC / EN 62208				
Clause	Requirement + Test	Result - Remark	Verdict	
	Tomporature within the exhibit 70 + 2°C			
	Temperature within the cabinet $70 \pm 2^{\circ}$ C		P	
	Enclosure kept in the cabinet for 7 days (168h)		Р	
	After the treatment:	1		
	relative humidity between 45% and 55% for 4 days (96h)		Ρ	
	<ul> <li>enclosure shows no crack without additional magnifications</li> </ul>		Р	
	- material became not sticky or greasy		Р	
	The forefinger wrapped in a dry piece of rough close is pressed with a force of 5N against the enclosure.		Ρ	
	No traces of the cloth remain to the enclosure and the material of the enclosure don't stick to the cloth.		Р	
9.8.2	Verification of resistance to heat			
	Temperature in the heating chamber 70 $\pm$ 2°C		N/A	
	The surface of the part to be tested is placed in the horizontal position and a steel ball of 5 mm diameter is pressed against the surface with a force of 20N.		N/A	
	Diameter of the impression caused by the steel ball not exceeding 2 mm	d = mm	N/A	
9.8.3	Verification of resistance to abnormal heat and to fire.			
	Test in accordance with the principles of IEC / EN 60695-2-10 and the details of IEC / EN 60695-2-11.		N/A	
	Tested as described in clause 4 of IEC / EN 60695-2-11		N/A	
	Apparatus used as described in clause 5 of IEC / EN 60695-2-11		N/A	
	Preconditioning of the samples:			
	Storage at 15 – 35°C / RH 35 – 45 % for 24h		N/A	
	Thermocouple of test apparatus calibrated in accordance with clause 6 of IEC / EN 60695-2-10		N/A	
	During test:			
	- clause 8 of IEC / EN 60695-2-10 followed		N/A	
	- clause 10 of IEC / EN 60695-2-11 followed		N/A	
	Temperature of the tip of the glow wire:	1		
	- for parts retaining live parts in positions 960 $\pm$ 15°C		N/A	
	Time at which sample ignited:	t <sub>i</sub> = s		



IEC / EN 62208				
Clause	Requirement + Test	Result - Remark	Verdict	
	Time when sample extinguished:	t <sub>e</sub> =s		
	- for parts intended to be installed in hollow walls $850 \pm 15^{\circ}C$		N/A	
	Time at which sample ignited:	ti = s		
	Time when sample extinguished:	t <sub>e</sub> =s		
	All other parts $650 \pm 15^{\circ}C$		N/A	
	Time at which sample ignited:	ti = S		
	Time when sample extinguished:	t <sub>e</sub> =s		
	No visible flame, no sustained glowing or flames and glowing extinguish within 30s		N/A	
	No burning of the tissue paper, no scorching of the pinewood board		N/A	
9.9	Verification of dielectric strength			
9.9.1	Preconditioning			
	Enclosures are placed in a humidity cabinet (relative humidity between 91% and 95%) and a air temperature of 40°C for 2 days (48h)		N/A	
9.9.2	Enclosures without metal elements inside the protective space			
	A r.m.s voltage according to 8.2.2.2 of IEC / EN 60439-1 is applied for 1 min. between 2 metal foils, one in contact with the external surface and the other inside the enclosure at the limit of the protected space.		N/A	
	Applied voltage:	U = V	N/A	
9.9.3	Enclosure having metal elements in the protected space			
	All internal metallic parts are connected to a bar, a voltage according to 8.2.2.2 of IEC / EN 60439-1 is applied for 1 min. between a metal foil in contact with the external surface and the bar.		N/A	
	Applied voltage:	U = V	N/A	
9.9.4	Results to be obtained			
	- samples show no damage impairing their further use		N/A	
	- no flashover or breakdown occurs during the test		N/A	
9.10	Verification of the continuity of the protective circuit			
	Exposed conductive parts of the enclosure connected to the protective circuit		Ρ	
	Resistance not exceeding 0,1 $\Omega$	Measured: 0,1 Ω	Р	
9.11	Verification of resistance to weathering.			



Г

IEC / EN 62208				
Clause	Requirement + Test	Result - Remark	Verdict	
	Samples of external parts constructed of synthetic materials or metals which are entirely coated by a synthetic material are tested		N/A	
	UV-test according to ISO / EN ISO 4892-2 method A, cycles of 5 min. of watering and 25 min. of dry period with xenon-lamp providing a total test period of 500h.		N/A	
	Temperature and humidity used for the test: - 65°C $\pm$ 3 °C; 65 $\pm$ 5 %RH or	Temperature: °C Humidity: %RH	N/A	
	- declared by the manufacturer			
	Compliance checked by verification:			
	- flexural strength (according to ISO / EN ISO 178) of synthetic materials have 70% min. retention		N/A	
	- charpy impact (according to ISO / EN ISO 179) of synthetic materials have 70% min. retention		N/A	
	After the test samples are subjected to the glow wire test of 9.8.3		N/A	
	After the test of 9.8.3 the adherence of protective coating of metal enclosures shall have 50 % minimum retention.		N/A	
	Samples show no cracks or deterioration		N/A	
9.12	Verification of resistance to corrosion			
	Metallic enclosures and external metallic parts of insulating and combined enclosures are tested to verify that they ensure protection against corrosion.		Р	
	In all cases hinges, locks and fastenings have to be tested.		Р	
9.12.1	Test procedure			
a)	Enclosures or metallic parts intended to be installed indoors and internal parts of enclosures intended to be installed outdoor.			
	- 6 cycles of 24h to damp heat cycling test according to test Db of IEC / EN 60068-2-30 at 40°C and relative humidity of 95% - 2 cycles of 24h to salt mist test according to test Ka of IEC / EN 60068-2-11 at a temperature of $35 \pm 2$ °C		NA	
b)	Enclosures or metallic parts intended to be installed outdoors.			
	The test comprises two identical 12 day periods.		Р	
	- 5 cycles of 24h each to damp heat cycling test according to IEC / EN 60068-2-30, test Db at 40°C and relative humidity of 95% - 7 cycles of 24h each to salt mist test according to IEC / EN 60068-2-11, test Ka at a temperature of $35 \pm 2$ °C			



IEC / EN 62208					
Clause	Requirement + Test	Result - Remark	Verdict		
9.12.2	Results to be obtained (after samples have been washed, water droplets have been removed and stored for 2h):				
	<ul> <li>no evidence of rust, cracking or other deterioration</li> <li>seals are not damaged</li> <li>doors, hinges, locks, fastenings and access</li> <li>means work without abnormal effort.</li> </ul>		Ρ		
	The different exposed conductive parts of the enclosure are effectively connected to the protective circuit according to 9.10		Ρ		



## ANNEX :







